



ನಗರಸಭಾ ಕಾರ್ಯಾಲಯ ಮಾದನಾಯಕನಹಳ್ಳಿ

ಬೆಂಗಳೂರು ಉತ್ತರ ತಾಲ್ಲೂಕು,

ಬೆಂಗಳೂರು ನಗರ ಜಿಲ್ಲೆ-562123,

Email : itstaff_ulb_mnhalli@yahoo.com

ದೂರವಾಣಿ ಸಂಖ್ಯೆ: 08023718487

ಸಂಖ್ಯೆ:ನೂ.ನ.ಕಾ/ತಾ.ಶಾ/ಸಿ.ಆರ್/03/2025-26

ದಿನಾಂಕ: 18/03/2026

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is Certified that an inspection team headed by Junior Engineer (Electrical) and Health Inspector from Local body Inspected the Oxford Public School, Srikantapura, Tumkur Road, Bangalore-560073 on 17.03.2026 and on the basis of Water Test Report (Attached) bearing Report no AESPLD/26/03/0226 dated 10.03.2026 Of AESLABS RESEARCH PVT LTD, Vinayakanagara, Bagalagunte, Bangalore-560073 certified that the Oxford Public School has safe drinking water Facilities for the students and members of staff of the institution through Borewell and Ro filter facility school is also maintains the hygienic sanitation condition in the school building.

Note:

1. This certificate is valid till 17.03.2027
2. Water Testing Should be done every month as per NABL Accredited Laboratory and that report should be posted on the notice board.

Municipal commissioner

CMC, Madanayakanahalli

Municipal Commissioner

CMC Madanayakanahalli

To,
The Principal,
Oxford Public School,
Srikantapura, Tumkur Road,
Bangalore-560073.



AESLABS RESEARCH PVT. LTD.

Formerly Known as AES Testing Laboratory

(ISO 9001:2015/ISO45001:2018/ISO 14001:2015 GLP Certified Laboratory)

44, 45, 1st Main Road, Vinayaka Nagar, Bagalagunte, Bangalore - 560 073.



Mob : 9538555792, 9538555283, 9000565208, Email : aestestinglaboratory@gmail.com Web : www.aeslabs.co.in

TEST REPORT

Report No : AESPLD/26/03/0226	Report Date	10/03/2026
Issued To: M/S, Oxford Public School, Anhepalya Anhepalya main road, Tumkur Rd, Nagasandra Post, Anhepalya, K.G.Srikantapura, Bengaluru, Karnataka 560073	Customer Reference	Verbal
	Date of collection	06/03/2026
	Date of sample receipt	06/03/2026
	Date of Commencement of analysis	06/03/2026
	Date of Completion of analysis	10/03/2026
	Sample number	AESPLD/26/03/0226
Sample Collected By: Customer	Number of pages	1 of 1
	Particular of sample	RO Water

Analytical Result

SL No	Test Parameter	Unit	Results	Limits As Per IS 10500		TEST METHOD
				Maximum Acceptable Limits	Permissible Limits in the Absence of Alternative Source	
1	Color	Hazen	<5.0	5	15	IS 3025 Part-04:2021
2	Odor	---	Agreeable	Agreeable	Agreeable	IS 3025 Part-05:2018
3	pH Value	---	6.8	6.5 - 8.5	No Relaxation	IS 3025 Part-11:2022
4	Electrical conductivity	µS/cm	54	Not specified	Not specified	IS 3025 Part-14:2013 RA 2023
5	Turbidity	NTU	<0.1	1	5	IS 3025 Part-10:2023
6	Total Dissolved Solids	mg/l	33.0	500	2000	IS 3025 Part-16:2023
7	Total Hardness as CaCO ₃	mg/l	7.0	200	600	IS 3025 Part-21:2009 RA 2023
8	Calcium as Ca	mg/l	2.0	75	200	IS 3025 Part-40:2024
9	Magnesium as Mg	mg/l	<1.0	30	100	IS 3025 Part-46:2023
10	Chloride as Cl	mg/l	12.0	250	1000	IS 3025 Part-32:2025
11	Total Alkalinity as CaCO ₃	mg/l	11.0	200	600	IS 3025 Part-23:2023
12	Residual Free Chlorine as Cl ₂	mg/l	<0.2	0.2 min	1.0	IS 3025 Part-26:2021
13	Sulphate as SO ₄	mg/l	5.0	200	400	IS 3025 Part-24:Sec1:2022
14	Nitrate as NO ₃	mg/l	3.0	45	No Relaxation	IS 3025 Part-34:Sec1:2023
15	Fluoride as F	mg/l	<0.1	1.0	1.5	IS 3025 Part-60:Sec1:2023
16	Iron as Fe	mg/l	<0.1	0.3	No Relaxation	IS 3025 Part-53:2024
17	Boron as B	mg/l	<0.25	0.5	1.0	IS 3025 Part-57:2021
18	Total Coliform	/100ml	Absent	Absent		IS: 15185:2016 RA 2021
19	E. Coli	/100ml	Absent	Absent		IS: 15185:2016 RA2021

Note: MPN: -Most Probable Number. RA: Reaffirmed

Remark: The above tested sample meets to the Acceptable limits for the physico-chemical parameters and meets to the biological parameters as per the requirements of IS 10500:2012 Reaffirmed 2023.

Tested By :

*****End of the Report*****



Note : 1. The Result listed pertain only to tested samples and applicable parameters. 2. Samples will be destroyed after 15 days from the date of issue of test certificate unless & otherwise Specified. 3. This Report is not be reproduced either wholly or in part and can not be used as an evidence in the count of law and should not any advertng media without prior Written permission. 4. Sampling not done by us, unless specified. 5. Laboratory is not responsible for the authenticity of photocopied Test Reports.